

WATER MAIN BREAK/JOINT LEAK REPORT JUNE 2018

YEARLY WATER MAIN BREAK COMPARISON

<u>JUNE 17</u>	<u>JUNE 18</u>	<u>YTD 17</u>	<u>YTD 18</u>
5	2	42	43

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	ESTIMATED DOLLAR VALUE OF WATER REVENUE LOSS**
1111 S. Madison Street	242220	DIP	12"	1972	4" hole	3 hours	445,636	\$2,709.47
Ballard Road/ Northland Avenue	242770	CIP	12"	1962	8" hole, 1/4" crack, 12' split	1.5 hours	1,629,538	\$9,907.59
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00

**Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.