

WATER SUMMARY FOR OCTOBER 2015

Work done by Construction Maintenance				
	Oct 14	Oct 15	YTD 14	YTD 15
Hydrants repaired	28	6	124	56
Hydrants replaced	0	0	2	6
Hydrant leaks	0	0	0	1
Valves replaced	0	0	6	5
Valves tested & inspected	0	0	0	17
Valves Rebuilt	0	0	22	9
Valve boxes repaired	28	6	159	142
Curb boxes repaired	33	9	228	398
Curb boxes replaced	36	43	226	184
Lead or galvanized replaced	2	0	5	0
New services 1"	0	0	1	0
New services >1"	3	1	8	4
Water main breaks	6	2	117	53
Joint leaks repaired	0	0	1	1
Water quality	1	1	14	4
Service leaks (City side)	0	0	3	0
Work done by Meter Service Team				
	Oct 14	Oct 15	YTD 14	YTD 15
New accounts set with 3/4" or 1"	16	2	53	91
New accounts set with larger meter	0	0	2	5
Meters tested	735	600	3263	6125
Meters failed	0	20	3	152
Meters stalled	0	0	3	4
Service calls	109	142	1304	1202
Final readings	344	321	3377	3395
Read meters - no reading	0	0	205	0
New meters installed	685	607	1197	6211
Exception meters inspected	0	0	2	0
Exception meters removed	0	0	1	0
Service leaks found	2	1	10	4
Cross connection inspections	610	596	2771	5793

**WATER MAIN BREAK/Joint LEAK REPORT OCTOBER
2015**

LOCATION	Work Order	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	ESTIMATED DOLLAR VALUE OF WATER REVENUE LOSS**
2519 N. McDonald Street	201808	CIP	8"	1964	1/8" crack	3 hours	98,191	\$597.28
3505 E. Lexington Drive	202645	DIP	8"	1964	1/16" crack	2 hours	92,050	\$559.93
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00

**Water loss is calculated at the residential rate of \$4.55 per 100 cubic feet.

**WATER MAIN BREAK/Joint LEAK DATA LOG OCTOBER
2015**

Leak Location	Arterial, Collector, Freeway, Local	Type of Street Concrete/Asphalt	Major Break Minor Break	Catch Basin Draining Yes/No	Date/Time	Comments
2519 N. McDonald Street	Local	Concrete	Major	Yes 240' away	10/3/2015 3:00 a.m. Saturday	Fixed right away. Coming up on both sides of the street.
3505 E. Lexington Drive	Local	Concrete	Minor	Yes 115' away	10/29/2015 10:10 p.m. Thursday	Fixed right away. Causing property damage.