



City of Appleton

100 North Appleton Street
Appleton, WI 54911-4799
www.appleton.org

Meeting Agenda - Final Board of Building Inspection

Monday, June 21, 2021

3:00 PM

6th Floor Council Chambers

1. Call meeting to order
2. Roll call of membership
3. Approval of minutes from previous meeting

4. Public Hearings/Apearances

[21-0898](#) Minutes from April 28, 2021

Attachments: [Minutes 4-28-21.pdf](#)

5. Action Items

[21-0896](#) **700 S. Weimar St. (31-4-1709-00)** The existing stairs leading to the basement has one riser that is nine (9) inches. Section 321.04(2)(b) of the Uniform Dwelling Code (UDC) limits riser height to eight (8) inches and uniform.

Attachments: [700 S. Weimar St.pdf](#)

[21-0897](#) **700 S. Weimar St. (31-4-1709-00)** The existing headroom on the stair is 5' 8", Section 321.04(2)(d) of the UDC requires the headroom to be 6'4".

Attachments: [700 S. Weimar St.pdf](#)

6. Information Items

7. Adjournment

Notice is hereby given that a quorum of the Common Council may be present during this meeting, although no Council action will be taken.

Reasonable Accommodations for Persons with Disabilities will be made upon Request and if Feasible.

