



...ting community needs...enhancing quality of life."

Department of Utilities
Wastewater Treatment Plant
2006 E Newberry Street
Appleton, WI 54915-3128
920-832-5945 tel.
920-832-5949 fax

To: Chairperson and Members of the Utilities Committee

From: Utilities Deputy Director, Chris Stempa

Date: April 20, 2020

Re: *Award AWWTP Final Clarifier Tank Underdrain Valve Vault Pipe Replacement to Piping Service Inc. in the amount in an amount not to exceed of \$17,800*

The underdrain collection system installed beneath the Appleton Wastewater Treatment Plant final clarifiers is designed to alleviate groundwater pressure exerted on the base of the concrete tanks. Discharge piping and valves within the tank drainage wetwell valve vault have become severely corroded and require replacement.

QUOTATIONS:

A request for quotation was conducted to solicit the necessary mechanical piping services required for a wholesale replacement of the wet well valve vault piping and associated valves. The work also includes pipe coating services and the installation of a stainless steel vent pipe. Quotations are summarized in the table below. Piping Service, Inc. was the least cost quote.

| Company | Base Bid |
|-----------------------------|-----------------|
| August Winter and Sons Inc. | \$21,100 |
| Great Lakes Mechanical | \$26,544 |
| Piping Service Inc. | \$17,800 |

RECOMMENDATION:

I am requesting award of the AWWTP Final Clarifier Tank Drainage Piping Replacement to Piping Service Inc. in the amount in an amount not to exceed of \$17,800. If you have any questions or require additional information regarding this project please contact Chris Stempa at 920-832-5945.