



"...meeting community needs...enhancing quality of life."

Department of Utilities
Wastewater Treatment Plant
2006 E Newberry Street
Appleton, WI 54915-3128
920-832-5945 tel.
920-832-5949 fax

TO: Chairperson William Siebers and Members of the Finance Committee

FROM: Utilities Director Chris Shaw

DATE: Thursday, April 07, 2022

RE: *Information Item: Change Order #2 to Staab Construction for the DAF Conversion to Receiving Tank Project in the amount of \$2,436 for the replacement of stainless steel tank fixtures and piping resulting in a decrease of contingency from \$15,551 to \$13,115*

BACKGROUND

The #2 Dissolved Air Flootation (DAF) Tank has been identified as an additional hauled waste receiving tank. The tank will provide an additional 35,000 gallons or a 50% increase in receiving station capacity. The DAF will also be able to revert to a DAF should the need arise. As a receiving station tank, a protective coating on all carbon steel components is required.

CHANGE ORDER #1

Change Order #2 is for both the replacement of fittings and steel piping in the tank that were corroded as well as for the addition of a wash water pipeline. The wash water pipeline system will be fabricated out of stainless steel piping and fittings. The change order cost includes all materials and labor expenses.

SUMMARY

Change Order #2 to Staab Construction for the DAF Conversion to Receiving Tank Project in the amount of \$2,436 for the replacement of tank wall carbon steel resulting in a decrease of contingency from \$15,551 to \$13,115