

# WATER MAIN BREAK/JOINT LEAK REPORT NOVEMBER 2018

## YEARLY WATER MAIN BREAK COMPARISON

<u>NOV 17</u>	<u>NOV 18</u>	<u>YTD 17</u>	<u>YTD 18</u>
11	7	69	73

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
2637 S. Jackson Street	248752	CIP	8"	1960	1/32" hole	331 days	64,202	\$390.35
211 W. Harriet Street	248780	CIP	6"	1962	5" hole	3 hours	531,889	\$3,233.89
2113 N. Douglas Street	248803	CIP	8"	1965	1/16" crack	8 hours	148,760	\$904.46
Beechwood Court / Pershing Street	248857	CIP	6"	1961	3/32" crack	36 hours	753,099	\$4,578.84
Memorial Drive / Seymour Street	248866	CIP	8"	1928	1/16" crack	4 hours	74,380	\$452.23
2503 S. Harmon Street	248957	CIP	8"	1968	16" split	3 days	405,701	\$2,466.66
2401 S. Harmon Street	248985	CIP	6"	1956	1/16" crack	12 hours	159,567	\$970.17
								\$0.00

\*\*Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.