

WATER MAIN BREAK/ JOINT LEAK REPORT - AUGUST 2020

YEARLY WATER MAIN BREAK COMPARISON

<u>AUG 19</u>	<u>AUG 20</u>	<u>YTD 19</u>	<u>YTD 20</u>
3	8	57	58

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
1532 S. Theodore St.	274305	DIP	8"	1975	1/32" Crack 3" Split	240 Days	5,010,243	\$30,462.28
3111 E. Rail Rd.	274360	DIP	12"	1978	4" Hole	3 Hours	429,426	\$2,610.91
2301 E. Lourdes Dr.	274475	CIP	12"	1963	1/32" Crack 18" Split	24 Hours	130,588	\$793.98
1115 E. Moorpark Ave.	274721	CIP	6"	1956	2" Hole	3 Hours	94,158	\$572.48
Pershing & Elinor	274871	CIP	8"	1969	1/8" Split	6 Hours	171,046	\$1,039.96
223 S. Lee St.	274867	CIP	6"	1941	20" Split	6 Hours	388,213	\$2,360.34
3217 E. Edgemere Dr.	274984	CIP	8"	1967	4" Hole	4 Hours	544,182	\$3,308.63
1312 E. Parkhills Dr.	275108	CIP	8"	1966	1/64" Crack 8" Split	240 Days	6,964,735	\$42,345.59

**Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.