

## WATER MAIN BREAK/ JOINT LEAK REPORT - JUNE

### YEARLY WATER MAIN BREAK COMPARISON

<u>MONTH 19</u>	<u>MONTH 20</u>	<u>YTD 19</u>	<u>YTD 20</u>
3	4	49	44

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
1701 W. Homestead Dr.	272146	DIP	8"	1975	4" Hole	4 Hours	757,944	\$4,608.30
2300 N. Linwood Av.	272369	CIP	8"	1979	1/32" Crack 10" Split	30 Days	2,176,475	\$13,232.97
3115 N. Ballard Rd.	272401	DIP	12"	1974	4" Hole	6 Hours	891,273	\$5,418.94
2626 N. Oneida St.	272736	DIP	12"	1979	1" x 3" Hole	5 Hours	847,769	\$5,154.44

\*\*Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.