



"...meeting community needs...enhancing quality of life."

Department of Utilities
Wastewater Treatment Plant
2006 E Newberry Street
Appleton, WI 54915
920-832-5945 tel.
920-832-5949 fax

TO: Chairperson Brad Firkus and Members of the Finance Committee

FROM: Chris Shaw, Utilities Director

DATE: November 30, 2022

RE: *Change Order #1 to Staab Construction Company in the amount of \$11,064 for Pump Pipe and Rail Replacement resulting in the reduction of contingency from \$11,850 to \$786*

The #1 Aeration Tank is one-million-gallon concrete tank that was constructed in 1964. The tank represents 20% of the wastewater treatment capacity. Structurally, the tank is in sound condition. However, the two tank drainage pumps have deteriorated discharge piping. Furthermore, the rails that guide the tank drainage pumps in and out of the tanks have also deteriorated. This change order replaces the six inch discharge piping for both pumps and replaces the pump rails on one pump. The new rails will be constructed of stainless steel which will enhance the life of the rails.

If you have any questions or require additional information regarding this project, please contact Chris Shaw at 920-832-5945.