



"...meeting community needs...enhancing quality of life."

Water Treatment Facility
2281 Manitowoc Rd.
Menasha, WI 54952
920-997-4200 tel.
920-997-3240 fax

TO: Chairperson Vered Meltzer and Members of the Utilities Committee

FROM: Utilities Director Chris Shaw

DATE: Thursday, November 07, 2019

SUBJECTS:

- *Change Order #1 to Classic Coatings in the amount of \$375 for the Lindbergh Painting Project resulting in the construction contract being increased to \$694,225 and a decrease in contingency from \$69,385 to \$69,010*

BACKGROUND

This change order is an aggregate of a number of minor changes to the original contract. This change order consists of the following items:

- Provide a new 30-inch sidewall manway with davit arm
- Provide davit on arm of existing 24-inch sidewall manway
- Adjust contract amount for Bid line Item 13 for the actual amount of structural evaluation used

If you have any questions or comments regarding this change order please contact me at ph: 832-2362.