

WATER MAIN BREAK/JOINT LEAK REPORT MAY

YEARLY WATER MAIN BREAK COMPARISON

<u>MAY 19</u>	<u>MAY 20</u>	<u>YTD 19</u>	<u>YTD 20</u>
4	3	46	40

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
Witzke Blvd.	270417	CIP	8"	1971	12" Split	7 Days	316,660	\$1,925.29
3111 E. Rail Rd.	270973	DIP	12"	1978	4" Hole	4 Hours	572,568	\$3,481.21
Melrose & Helen	271400	CIP	6"	1953	3" Hole	4 Hours	317,914	\$1,932.92

**Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.