

WATER MAIN BREAK/JOINT LEAK REPORT JULY 2018

YEARLY WATER MAIN BREAK COMPARISON

<u>JULY 17</u>	<u>JULY 18</u>	<u>YTD 17</u>	<u>YTD 18</u>
3	5	45	48

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	ESTIMATED DOLLAR VALUE OF WATER REVENUE LOSS**
Benoit Street/ Spencer Street	243443	CIP	6"	1929	3" hole	4 hours	326,172	\$1,983.13
Rankin Street/ Grant Street	243848	CIP	6"	1957	3" hole	3 hours	200,255	\$1,217.55
1410 E. Harriet Street	243850	CIP	6"	1962	5" hole	5 hours	886,483	\$5,389.82
Reid Drive/ Hycrest Drive	244025	CIP	6"	1928	3' x .25" split & 3" hole	8 hours	1,007,834	\$6,127.63
Fair Street/ Commercial Street	244316	CIP	4"	1913	1/16" crack & 16" split	8 hours	65,664	\$399.24
								\$0.00
								\$0.00
								\$0.00

**Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.