

Nathan Williams

From: Crystal Williams <crystal.k.denton@gmail.com>
Sent: Tuesday, June 4, 2024 3:02 PM
To: Nathan Williams
Subject: Fwd: Corner Pub
Attachments: image001.jpg; Inspection-Letter_05-30-2024.pdf

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

----- Forwarded message -----

From: Michelle Roberts <Michelle.Roberts@appleton.org>
Date: Mon, Jun 3, 2024, 10:29
Subject: Corner Pub
To: crystal.k.denton@gmail.com <crystal.k.denton@gmail.com>

Attached is the notes from Electrical and Fire


Below is the list of violations that I noticed at the Corner Pub on 1123 N Mason. A licensed electrical contractor will need to apply for a permit and perform the work. Once Kurt creates a CSR I will put the notes in. Let me know if you have any questions.

- Boxes without covers – 314.25
- Open splices – 300.15
- Flex conduit not connected to the light fixtures – 300.12
- Lights not secured to the grid – 410.36(B)
- GFCI protection within 6' of sink – 210.8(B)(5)
- GFCI in unfinished basement – 210.(B)(10)
- NM not secured at panel – 334.30
- EMT conduit not properly secured – 358.30
- Damaged receptacles and covers – 110.12(B)

-Box extensions needed – 314.20

-Box fill – 314.16

Thank you,



Timothy Meyer

Electrical Inspector

City of Appleton, Community Development Department

100 N. Appleton Street, Appleton, WI 54911

O: 920-832-5806 | timothy.meyer@appletonwi.gov

Appleton.org



Appleton Fire Department Inspection Report

Business Information

Occupant Name: Corner Bar **Date Completed:** 05/30/2024
Address: 1123 N MASON ST **IFC Classification:** A2 - Assembly
Business Phone:
Occupant Suite:
City: APPLETON **State:** WI **Postal Code:** 54914

Contact Information

First Name Kim **Last Name** Williams
Cell Phone 920-450-8456

Inspection Information

Inspection Type: Routine

Violations

Complaint Reported Date	Violation Code	Violation Status	Re-Inspection Date	Description	Comments
12:29:26	603.2.2	Violation Noted - Schedule Recheck	06/26/2024	Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes.	Multiple junction boxes open, no expose wiring allowed
12:32:31	703.1.3	Violation Noted - Schedule Recheck	06/26/2024	Required fire walls, fire barriers and fire partitions shall be maintained to prevent the passage of fire. Openings protected with approved doors or fire dampers shall be maintained in accordance with NFPA 80.	Breach of fire walls different locations
12:35:07	NFPA 1:14.13.2 .1.1	Violation Noted - Schedule Recheck	06/26/2024	Emergency Lighting – Shall be function tested monthly for not less than 30 seconds and annually function tested for a minimum of 90 minutes. A written record of visual inspections and tests shall be kept for inspection.	Emergency light not working

For a list of companies that may complete this service, please copy the below link and paste it in your browser. Please be aware that this is not a complete list of vendors and is provided as a courtesy.

<https://drive.google.com/open?id=1hXhLNNiIR34frMu-pNc-wLhFRqAnuxd6>

For an example test record, please copy the link and paste it in your browser.

https://drive.google.com/open?id=1MBznFpMIwiBixVvi4et2T-_0bvi8qAAe

Inspected by: DETERT, JEREMIAH

Date Completed: 05/30/2024

12:35:33	315.3.3	Violation Noted - Schedule Recheck	06/26/202 4	Combustible material shall not be stored in boiler rooms, mechanical rooms, electrical equipment rooms or in fire command centers as specified in Section 508.1.5.	No storage allowed under the stairway to basement unless is protected by sprinkler system
----------	---------	---	----------------	--	--

Violation Documents

Document File Not Found.

Document File Not Found.

Document File Not Found.

Document File Not Found.

Order to Comply

As such conditions are contrary to law, you are hereby required to correct said violations upon receipt of this notice. An inspection to determine whether or not you have complied with this notice will be conducted approximately on or around the date listed above. Failure to comply before the reinspection date may render you liable to the penalties provided by law for such violations, and reinspection or missed appointment fees.