

WATER SUMMARY FOR JUNE 2013

Work done by Construction Maintenance				
	<u>June 12</u>	<u>June 13</u>	<u>YTD 12</u>	<u>YTD 13</u>
Hydrants repaired	8	22	268	69
Hydrants replaced	1	0	2	3
Hydrant leaks	0	0	0	0
Valves replaced	1	0	2	2
Valves tested & inspected	374	304	440	304
Valves Rebuilt	0	4	3	10
Valve boxes repaired	4	23	63	74
Curb boxes repaired	53	30	177	106
Curb boxes replaced	28	70	104	101
Lead or galvanized replaced	14	5	36	5
New services 1"	0	0	0	2
New services >1"	3	2	4	4
Water main breaks	1	4	32	54
Joint leaks repaired	0	0	0	3
Water quality	0	1	7	7
Service leaks (City side)	0	0	1	3
Work done by Meter Service Team				
	<u>June 12</u>	<u>June 13</u>	<u>YTD 12</u>	<u>YTD 13</u>
New accounts set with 3/4" or 1"	6	16	22	109
New accounts set with larger meter	0	0	3	0
Meters tested	107	59	920	141
Meters failed	3	0	15	1
Meters stalled	1	1	18	16
Service calls	64	78	528	715
Final readings	365	339	1806	1802
Read meters - no reading	3	4	85	79
Defective trace replaced	0	1	12	3
Exception meters inspected	0	0	1	0
Exception meters removed	0	0	1	0
Service leaks found	2	0	3	3
Batteries changed	93	9	802	95

**WATER MAIN BREAK/JOINT LEAK REPORT JUNE
2013**

LOCATION	Work Order	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	ESTIMATED DOLLAR VALUE OF WATER REVENUE LOSS**
209 N. Oneida Street	161840	CIP	6"	Unknown	1" hole	6 hours	60,000	\$364.97
1133 W. Northland Avenue	161760	CIP	12"	1969	1/4" hole	30 days	900,000	\$5,474.60
McKinley Street/Jefferson Street	162098	CIP	4"	1913	1/16" crack	30 days	5,472,000	\$33,285.56
Kensington Drive/Warehouse Road	162824	DIP	12"	1977	4" hole	4 hours	640,000	\$3,893.05
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00

**Water loss is calculated at the residential rate of \$4.55 per 100 cubic feet.

**WATER MAIN BREAK/JOINT LEAK DATA LOG JUNE
2013**

Leak Location	Arterial, Collector, Freeway, Local	Type of Street Concrete/Asphalt	Major Break Minor Break	Catch Basin Draining Yes/No	Date/Time	Comments
209 N. Oneida Street	Collector	Concrete	Major	Yes 50' away	6/3/2013 8:00 a.m. Monday	Fixed right away. Located by the bus station.
1133 W. Northland Avenue	Collector	Concrete	Minor	No	6/7/2013 8:00 a.m. Friday	Fixed right away. The ground was soft, indicating it had been running for some time. Discovered while mowing the lawn.
McKinley Street/ Jefferson Street	Local	Concrete	Minor	No	6/14/2013 8:00 a.m. Friday	Found the leak while testing hydrants. It had been running a long time. The water was not coming to the surface.
Kensington Drive/ Warehouse Road	Collector	Concrete	Major	Yes 250' away	6/24/2013 7:00 a.m. Monday	Fixed right away. There was a lot of water and mud with the potential for significant property damage.