



"...ing community needs...enhancing quality of life."

Department of Utilities
Wastewater Treatment Plant
2006 E Newberry Street
Appleton, WI 54915-3128
920-832-5945 tel.
920-832-5949 fax

To: Chairperson Vered Meltzer and Members of the Utilities Committee

From: Utilities Director Chris Shaw

Date: August 29, 2022

Re: *Approval of a Coating Services Contract for the DAF and Receiving Station Tanks to Badger Specialties Coatings in the amount of \$59,000 with a contingency of \$5,900 for a total not to exceed cost of \$64,900*

Background:

The Appleton Wastewater Treatment Plant (AWWTP) staff has identified that four tanks are in need of exterior maintenance. Each of the tanks has a volume of 35,000 gallons and is constructed out of carbon steel. The tank exteriors were coated 40 years ago. Since that time blisters and corrosion has occurred. This project will properly restore the tanks exteriors with an exterior protective coating system.

McMahon was asked to deliver coating specifications and quotation documents for the tank repair. Three qualified coating contractors were invited to provide quotes for the tank work. The results of which are summarized below.

Quotation Process:

The three qualified contractors were invited based on their prior work within the water, wastewater, and industrial sectors. Two quotations were received that met qualifications defined in the Request for Quote (RFQ). Badger Specialties Coatings had the lowest cost quotation at \$56,800. Saint Germain Sandblasting and Painting did not submit a proposal. The following table summarizes the company quotes.

Contractor	Quote
Mississippi Valley Coatings	\$67,850
Saint Germain Sandblasting	DNP
Badger Specialties Coatings	\$56,800

*DNP – Did Not Propose

Recommendation:

I recommend approval of a Coating Services Contract for the DAF and Receiving Station Tanks to Badger Specialties Coatings in the amount of \$56,800 with a contingency of \$5,700 for a total not to exceed cost of \$62,500

If you have any questions, regarding the project please contact Chris Shaw at 832-2362.