

WATER MAIN BREAK/JOINT LEAK REPORT JANUARY 2019

YEARLY WATER MAIN BREAK COMPARISON

<u>JAN 18</u>	<u>JAN 19</u>	<u>YTD 18</u>	<u>YTD 19</u>
17	12	17	12

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
905 N. Kensington Drive	250679	CIP	8"	1969	1/16" crack	6 hours	106,000	\$644.48
603 E. Goodall Street	250899	CIP	6"	1937	1/16" crack	9 days	644,000	\$3,915.52
425 S. Covenant Lane	250970	DIP	8"	1980	Two 3" holes	5 hours	1,662,698	\$10,109.20
1507 N. Edgewood Avenue	251107	CIP	8"	1961	3/16" crack	6 hours	300,172	\$1,825.05
419 S. Arlington Street	251129	CIP	6"	1961	1/64" crack	17 days	304,125	\$1,849.08
12 Weimar Court	251232	CIP	6"	1936	1/8" crack	4 hours	67,279	\$409.06
2425 N. Division Street	251285	CIP	6"	1957	1/8" crack	4 hours	70,618	\$429.36
2901 Crestview Drive	251287	CIP	8"	1966	4" hole	6 hours	851,023	\$5,174.22

**Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.

WATER MAIN BREAK/JOINT LEAK REPORT JANUARY 2019

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
Linwood Avenue / Cloverdale Avenue	251411	DIP	8"	1978	1/32" crack	23 days	3,516,918	\$21,382.86
2525 N. Roemer Road	251494	CIP	12"	1969	1/64" crack	24 days	3,137,575	\$19,076.46
Forest Street / Christine Street	251647	CIP	6"	1956	2" crack	3 hours	2,104,356	\$12,794.48
Clara Street / Rail Road	251667	DIP	8"	1977	6" hole	3 hours	1,094,015	\$6,651.61
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00

**Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.