

WATER MAIN BREAK/JOINT LEAK REPORT AUGUST 2019

YEARLY WATER MAIN BREAK COMPARISON

<u>AUG 18</u>	<u>AUG 19</u>	<u>YTD 18</u>	<u>YTD 19</u>
6	3	42	57

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
1221 E Northland Ave	259400	DIP	12"	1979	6" hole	3 Hours	1,130,681	\$6,874.54
Lawrence St and Oneida St	259556	CIP	6"	Pre 1930	6" Hole	3 Hours	902,148	\$5,485.06
1710 E Northland Ave	260219	DIP	12"	1976	1/16" Hole	72 Hours	2,493	\$15.16
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00

**Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.