

# WATER MAIN BREAK/JOINT LEAK REPORT AUGUST 2018

## YEARLY WATER MAIN BREAK COMPARISON

<u>AUG 17</u>	<u>AUG 18</u>	<u>YTD 17</u>	<u>YTD 18</u>
4	6	49	54

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	ESTIMATED DOLLAR VALUE OF WATER REVENUE LOSS**
Seminole Road/ Cherokee Drive	244837	CIP	8"	1961	1/8" crack	4 hours	72,934	\$443.44
1217 E. Mitchell Avenue	244853	CIP	8"	1966	1/16" crack	5 hours	75,973	\$461.92
2701 E. Winslow Avenue	244997	DIP	12"	1978	1/8" crack	6 hours	259,469	\$1,577.57
Clara Street/ Forest Street	245071	DIP	8"	1975	6" hole	3 hours	1,094,015	\$6,651.61
3137 N. Roemer Road	245123	DIP	12"	1980	3.5" hole	5 hours	550,000	\$3,344.00
2908 E. Henry Street	245542	DIP	8"	1980	5" hole	4 hours	850,284	\$5,169.73
								\$0.00
								\$0.00

\*\*Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.