



*"...meeting community needs...enhancing quality of life."*

**PARKS, RECREATION & FACILITIES  
MANAGEMENT**

**Dean R. Gazza, Director**

1819 East Witzke Boulevard  
Appleton, Wisconsin 54911-8401  
(920) 832-5572 FAX (920) 993-3103  
Email - [dean.gazza@appleton.org](mailto:dean.gazza@appleton.org)

TO: Utilities Committee

FROM: Dean R. Gazza

DATE: 11/11/2014

RE: Informational: Change Order # 1 for Wastewater Fire Protection System, Phase III, to increase for additional fire alarm cable in the amount of \$3,106 resulting in a decrease to the contingency from \$10,000 to \$6,894. No Change to overall contract amount.

This memo is to inform the Committee of Change Order #1 in the amount of \$3,106 to Faith Technologies for additional work to this project to provide Phase III of the Fire Protection System at the Wastewater Plant. This change order is to provide fire alarm cable from the FG Tunnel to the H and J Buildings. This work was not included in the original design documents because the designer believed it would discourage some companies from bidding due to the confined space work associated with making this cable run. The original plan was for the City to accomplish this portion of the job, but with multiple vacancies and an increased number of work requests, we were not able to do the work in-house.

Please feel free to contact me at 832-5572 or at [dean.gazza@appleton.org](mailto:dean.gazza@appleton.org).