

WATER MAIN BREAK/JOINT LEAK REPORT MAY 2019

YEARLY WATER MAIN BREAK COMPARISON

<u>MAY 18</u>	<u>MAY 19</u>	<u>YTD 18</u>	<u>YTD 19</u>
4	4	41	46

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
312 E. Franklin Street	256384	CIP	8"	1912	split 30"	4 hours	386,553	\$2,350.24
312 E. Franklin Street	256384	CIP	8"	1912	split 30"	30 minutes	40,562	\$246.62
711 E. Capitol Drive	256481	DIP	12"	1978	6"	4 hours	1,383,832	\$8,413.70
312 E. Franklin Street	256384	CIP	8"	1912	6"	3 hours	1,026,278	\$6,239.77
								\$0.00
								\$0.00
								\$0.00
								\$0.00

**Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.