

August 28, 2018 Storm Update

Rain Event

- Southside Rain Gauge data showed 1.96 inches in 1 hour and 2.73 inches in 21 hours. This data is consistent to the statistical 25-year event for this area.

Street Flooding

- Locations of known flooding (all subsided within 3 hours after end of rain event):
 - Ballard- (Glendale to Pershing) 2 feet of water, manhole covers pop off, became unpassable, shut down with barricades
 - Ballard- (Amelia to Railroad Tracks) 2 feet of water, became unpassable
 - Northland /Meade- intersection flooded, water completely covering roadway E/O Meade on OO, manhole covers pop off, became unpassable
 - Mason/Edmund- intersection flooded, manhole cover off
 - Pershing/Lillian- intersection flooded (a lot of water coming from Northland) became unpassable
 - Lillian Ct, Viola Ct, Oakwood Ct, & Beechwood Ct between Service Rd and Pershing- flooded, water all the way up to the houses (a lot of water coming from Northland) became unpassable
 - Glendale- (Charlotte to Owaissa)- flooded, became unpassable
 - Glendale/Union- Flooded
 - Wisconsin- (Ballard to Meade) flooded
 - Meade St.- (Arnold to Roosevelt) road completely flooded, became unpassable
 - Richmond/Parkway- intersection flooded, became unpassable
 - Richmond/Brewster- intersection flooded, became unpassable
 - Richmond/ College- intersection flooded, mainly on Richmond N/O College, became unpassable
 - Lindbergh/Appleton- manhole cover off
 - Pershing/Appleton- manhole cover off
 - Michigan/Appleton- manhole cover off
 - Superior/Marquette- intersection flooded
 - South River/ Olde Oneida- intersection flooded
 - 1600 Blk of S Lawe- flooded, became unpassable
 - 1705 E John- manhole cover off
 - Calumet/Schaefer- intersection flooded, water shooting out of manhole 3ft, became unpassable
 - Calumet/Mathias- intersection flooded, water shooting out of manhole 3ft, became unpassable
 - Calumet/ Telulah- intersection flooded, manhole cover off
 - Christine/Forest- manhole cover off
 - Oneida/Atlantic- intersection flooded, manhole cover off

- Jackman/Water- manhole cover off
- Plank Rd/ Lake Park roundabout- flooded, became unpassable
- Lake Park Road under 441 Overpass- bank washing onto sidewalk and roadway, put out sandbags
- Railroad underpass- Mason St.- 5ft on water level marker, shut down with barricades
- Railroad underpass- Wisconsin Ave- 3ft on water level marker
- Haymeadow Avenue
- 1813 E. Grant Street
- 1318 W. Second Street
- N. Ullman Street
- 1200 E. Frances Street
- 1014 E. Meadow Grove Boulevard
- Service Road/McDonald Street
- 3725 Hampton Court
- 811 S. Kernan Avenue

Basement Flooding

- 806, 822, & 828 W Franklin- water coming up through floor drains in basements, checked in sanitary manholes on Franklin and the system was full of rain water, possible leak somewhere on sanitary main.
- 130 N Morrison- water running in basement, no sump pump

Power Outages

- None

Tree Damage

- 22 Weather Stone Dr- tree branch
- 603 W Parkway Blvd- tree branch

NOTE

- Our contractor just completed the connection of the 72-inch storm sewer to the Northland Pond the morning of the storm. The pond water level reached 7 feet!

