

# WATER MAIN BREAK/JOINT LEAK REPORT FEBRUARY 2019

## YEARLY WATER MAIN BREAK COMPARISON

<u>FEB 18</u>	<u>FEB 19</u>	<u>YTD 18</u>	<u>YTD 19</u>
7	11	24	23

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
1432 S. Memorial Drive	251796	CIP	8"	1928	4" crack	2 hours	1,925,000	\$11,704.00
Matthias Street / Forest Street	252149	CIP	8"	1963	1/128" crack	8 hours	16,801	\$102.15
1517 W. Prospect Avenue	252316	CIP	6"	pre 1930	1/64" crack	43 days	2,369,421	\$14,406.08
1425 N. Drew Street	252356	CIP	6"	1920	1/8" crack	12 hours	225,537	\$1,371.26
900 E. Glendale Avenue	252667	CIP	8"	1952	3" hole	5 hours	407,716	\$2,478.91
1631 S. Lynndale Drive	252861	CIP	8"	1961	1/32" crack	7 days	1,053,496	\$6,405.26
1600 W. Prospect Avenue	252887	CIP	8"	1957	1/8" crack	8 hours	214,713	\$1,305.46
1613 S. Carver Lane	252905	CIP	6"	1952	2" hole	4 hours	178,927	\$1,087.88

\*\*Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.

## WATER MAIN BREAK/JOINT LEAK REPORT FEBRUARY 2019

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
1437 E. Harriet Street	252986	CIP	6"	1937	1/16" crack	12 hours	135,928	\$826.44
727 W. Weiland Avenue	252998	CIP	8"	1969	1/64" crack	56 days	2,565,694	\$15,599.42
Locust Street / Franklin Street	253146	CIP	6"	1948	1/8" crack	1 day	394,453	\$2,398.27
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00

\*\*Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.