



"...meeting community needs...enhancing quality of life."

Department of Utilities
Wastewater Treatment Plant
2006 E Newberry Street
Appleton, WI 54915-3128
920-832-5945 tel.
920-832-5949 fax

TO: Chairperson Brad Firkus and Members of the Finance Committee

FROM: Utilities Director Chris Shaw

DATE: Thursday, May 19, 2022

RE: *Information Item: Change Order #3 to Staab Construction for the DAF Conversion to Receiving Tank Project in the amount of \$10,495 for the replacement of tank carbon steel header to stainless steel resulting in a decrease of contingency from \$13,115 to \$2,620*

BACKGROUND

The #2 Dissolved Air Flootation (DAF) Tank has been identified as an additional hauled waste receiving tank. The tank will provide an additional 35,000 gallons or a 50% increase in receiving station capacity. The DAF will also be able to revert to a DAF should the need arise. As a receiving station tank, a protective coating on all carbon steel components is required.

CHANGE ORDER #3

Change Order #3 is for both the replacement of deteriorated carbon steel header in the tank and for the fabrication and installation of a new 316 stainless steel header. The project cost includes all materials and labor to accomplish the objectives.

SUMMARY

Change Order #3 to Staab Construction for the DAF Conversion to Receiving Tank Project in the amount of \$10,495 for the replacement of the carbon steel header with a fabricated stainless-steel header resulting in a decrease of contingency from \$13,115 to \$2,620