

WATER MAIN BREAK/JOINT LEAK REPORT JULY 2019

YEARLY WATER MAIN BREAK COMPARISON

<u>JULY 18</u>	<u>JULY 19</u>	<u>YTD 18</u>	<u>YTD 19</u>
2	5	42	54

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
Hancock/ Durkee St	258108	CIP	8"	1912	0.0625" Crack	12 hours	159,000	\$966.72
3129 N Lawe St	258142	CIP	8"	1967	6" Hole	4 hours	1,325,890	\$8,061.41
2100 N Birchwood	258312	CIP	8"	1964	4" Hole	5 hours	822,009	\$4,997.81
Fifth/ Locust St	258302	CIP	12"	1963	1/32x 16" Split	4800 hours	11,133,870	\$67,693.93
807 W Commerical St	258761	PVC	8"	1998	4" Hole	3 hours	1,676,049	\$10,190.38
								\$0.00
								\$0.00
								\$0.00

**Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.