

## WATER MAIN BREAK/ JOINT LEAK REPORT - NOVEMBER 2020

### YEARLY WATER MAIN BREAK COMPARISON

<u>MONTH 19</u>	<u>MONTH 20</u>	<u>YTD 19</u>	<u>YTD 20</u>
15	7	85	78

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
507 S. Fidelis St.	278549	CIP	8"	1970-1979	1/16" Crack	12 Hours	171,046	\$1,039.96
NOTES: Resident called in, sump pump running.								
1120 N. Divison St.	278593	DIP	12"	1970	3" Hole	4 Hours	434,227	\$2,640.10
NOTES: Break was found as water was on the road.								
2415 S. Madison St.	278715	CIP	6"	1956	1/16" Crack	4 Hours	45,584	\$277.15
NOTES: Called in for water bubbling up. Call came in quickly after it started.								
1624 E. Moon Beam Tr.	278771	DIP	8"	1984	6" Hole	2.5 Hours	809,834	\$4,923.79
NOTES: Water bubbling up was called in by resident.								

\*\*Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
Northland Ave. & Roemer Rd.	27821		12"	2020	Joint Leak	1.5 Hours	135,000	\$820.80
NOTES: Reported by the County.								
1818 E. Glendale Ave.	278847	CIP	8"	1952	8" Hole	4 Hours	2,029,810	\$12,341.24
NOTES: PD reported as water was running down the road.								
2525 N. Brookdale Ct.	278870	CIP	8"	1961	1/8" Crack	10 Hours	278,525	\$1,693.43
NOTES: Called in for water in road. Duration is based on the time of call and soil saturation.								

\*\*Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.