

# WATER MAIN BREAK/JOINT LEAK REPORT NOVEMBER 2019

## YEARLY WATER MAIN BREAK COMPARISON

<u>NOV 18</u>	<u>NOV 19</u>	<u>YTD 18</u>	<u>YTD 19</u>
7	15	73	85

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
Lynn & Newberry	262782	CIP	8"	1961	Two 2" Holes	6 Hours	476,406	\$2,896.55
419 S. Schafer St.	262783	CIP	8"	1965	1/8" Crack	4 Hours	119,101	\$724.13
325 S. Summit St.	262844	CIP	6"	1927	12" Split 1/4" Hole	5 Hours	40,000	\$243.20
707 S. Joseph St.	263084	CIP	8"	1963	1/16" Crack	12 Hours	189,500	\$1,152.16
Capitol & Rankin	263115	CIP	8"	1967	1/32" Crack	8 Hours	60,800	\$369.66
619 E. Lindbergh St.	263215	CIP	8"	1952	3/32" Crack	2 Hours	38,679	\$235.17
1115 E. Moorpark Av.	263214	CIP	6"	1956	2" Hole	4 Hours	125,500	\$763.04
3207 N. Rankin St.	263264	CIP	8"	1967	1/16" Crack	4 Hours	60,780	\$369.54

\*\*Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.

## WATER MAIN BREAK/JOINT LEAK REPORT NOVEMBER 2019

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
2515 E. Newberry St.	263263	CIP	12"	1960	1/34" Split	48 Hours	86,950	\$528.66
924 S. Clara St.	263371	CIP	8"	1972	4" Hole	3 Hours	486,229	\$2,956.27
500 W. Parkway Bl.	263648	CIP	6"	1945	1/16" Crack	5 Hours	44,000	\$267.52
1825 E. Cedarwood Dr.	263679	PVC	8"	1987	1/64" Crack	60 Days	4,892,586	\$29,746.92
Kensington & Warehouse	263717	DIP	12"	1977	2" Hole	5 Hours	227,400	\$1,382.59
300 E. Cardinal Pl.	263874	CIP	8"	1967	8" Split 1/32" Crack	30 Days	1,706,001	\$10,372.49
500 E. First Av.	263937	CIP	8"	1965	1/16" Crack	16 Hours	228,062	\$1,386.62

\*\*Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.