

WATER MAIN BREAK/JOINT LEAK REPORT SEPTEMBER 2018

YEARLY WATER MAIN BREAK COMPARISON

<u>SEPT 17</u>	<u>SEPT 18</u>	<u>YTD 17</u>	<u>YTD 18</u>
3	2	52	56

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	ESTIMATED DOLLAR VALUE OF WATER REVENUE LOSS**
Jackman Street/ Water Street	245795	DIP	16"	1971	4" hole	11 hours	1,130,000	\$6,870.40
Kernan Avenue/ Meadow Grove Boulevard	245970	DIP	12"	1978	5" hole	6.5 hours	1,297,334	\$7,887.79
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00

**Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.