

WATER SUMMARY FOR SEPTEMBER 2014

Work done by Construction Maintenance				
	Sept 13	Sept 14	YTD 13	YTD 14
Hydrants repaired	47	10	158	96
Hydrants replaced	0	0	3	2
Hydrant leaks	0	0	1	0
Valves replaced	0	0	2	6
Valves tested & inspected	0	0	869	0
Valves Rebuilt	1	1	22	22
Valve boxes repaired	19	7	141	131
Curb boxes repaired	16	25	165	195
Curb boxes replaced	27	24	186	190
Lead or galvanized replaced	0	3	15	3
New services 1"	0	1	2	1
New services >1"	1	0	6	5
Water main breaks	3	2	62	111
Joint leaks repaired	0	0	3	1
Water quality	3	0	12	13
Service leaks (City side)	0	0	3	3
Work done by Meter Service Team				
	Sept 13	Sept 14	YTD 13	YTD 14
New accounts set with 3/4" or 1"	20	18	196	37
New accounts set with larger meter	1	0	1	2
Meters tested	44	554	217	2528
Meters failed	1	0	2	3
Meters stalled	6	0	25	3
Service calls	64	141	950	1195
Final readings	389	414	3060	3033
Read meters - no reading	16	0	118	205
Defective trace replaced	0	0	3	0
Exception meters inspected	0	0	0	2
Exception meters removed	0	0	0	1
Service leaks found	0	2	3	8
Cross connection inspections	0	512	0	2161

**WATER MAIN BREAK/JOINT LEAK REPORT SEPTEMBER
2014**

LOCATION	Work Order	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	ESTIMATED DOLLAR VALUE OF WATER REVENUE LOSS**
East Street/ Taft Avenue	182158	CIP	6"	1968	1/16" crack	6 hours	68,400	\$416.07
Locust Street/ Harris Street	182370	CIP	6"	1948	1/16" crack	6 hours	68,400	\$416.07
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00

**Water loss is calculated at the residential rate of \$4.55 per 100 cubic feet.

**WATER MAIN BREAK/JOINT LEAK DATA LOG SEPTEMBER
2014**

Leak Location	Arterial, Collector, Freeway, Local	Type of Street Concrete/Asphalt	Major Break Minor Break	Catch Basin Draining Yes/No	Date/Time	Comments
East Street/ Taft Avenue	Local	Concrete	Major	Yes 10' away	9/19/2014 7:00 a.m. Friday	Fixed during normal work hours.
Locust Street/ Harris Street	Local	Asphalt	Major	Yes 10' away	9/25/2014 10:00 AM Thursday	Fixed during normal work hours.