

WATER MAIN BREAK/JOINT LEAK REPORT MAY 2018

YEARLY WATER MAIN BREAK COMPARISON

<u>MAY 17</u>	<u>MAY 18</u>	<u>YTD 17</u>	<u>YTD 18</u>
4	4	37	41

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	ESTIMATED DOLLAR VALUE OF WATER REVENUE LOSS**
1707 W. Weiland Lane	240562	DIP	8"	1980	2" hole	5 hours	278,345	\$1,692.34
624 E. Mitchell Avenue	241214	DIP	8"	1978	2" hole	4 hours	126,863	\$771.33
7 South Meadows Drive	241298	CIP	6"	1960	1/8" crack & 24" split	8 hours	103,824	\$631.25
Arlington Street/ John Street	241769	DIP	12"	1974	5" hole	4 hours	1,012,977	\$6,158.90
								\$0.00
								\$0.00
								\$0.00
								\$0.00

**Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.