

# WATER MAIN BREAK/ JOINT LEAK REPORT - OCTOBER 2020

## YEARLY WATER MAIN BREAK COMPARISON

<u>OCT 19</u>	<u>OCT 20</u>	<u>YTD 19</u>	<u>YTD 20</u>
9	5	70	71

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
Northland Ave. (West of Ballard)	276849	DIP	12"	1976	4" Hole	3 Hours	536,229	\$3,260.27
NOTES: Received report of water coing of of the road.								
Roemer Rd. (South of Capitol Dr.)	277284	DIP	12"	1980	3/16" Hole	176 Days	1,620,150	\$9,850.51
NOTES: Leak was found with the correlator. Estimated duration is based on soil saturation and the date of a previous main break in that area.								
1512 S. Memorial Dr.	277478	CIP	8"	1928	2" Hole	4 Hours	162,076	\$985.42
NOTES: Received call from APD of water bubbling out of road.								
2915 S. Gladys Ave.	277589	CIP	8"	1966	1/32" Crack	4 Hours	29,775	\$181.03
NOTES: Received report of water was bubbling on surface.								
3421 E. Crestview Dr.	277782	CIP	8"	1964	1/16" Crack	4 Hours	57,015	\$346.65
NOTES: Reported by the Sanitation Dept. picking up cans.								

\*\*Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.