

WATER SUMMARY FOR NOVEMBER 2013

Work done by Construction Maintenance				
	<u>Nov 12</u>	<u>Nov 13</u>	<u>YTD 12</u>	<u>YTD 13</u>
Hydrants repaired	18	13	390	195
Hydrants replaced	0	0	6	3
Hydrant leaks	0	0	0	1
Valves replaced	0	2	5	4
Valves tested & inspected	0	0	704	869
Valves Rebuilt	5	1	13	24
Valve boxes repaired	6	8	112	161
Curb boxes repaired	18	17	323	200
Curb boxes replaced	29	46	222	235
Lead or galvanized replaced	0	2	36	24
New services 1"	0	0	0	2
New services >1"	0	0	6	6
Water main breaks	11	9	74	79
Joint leaks repaired	4	0	4	3
Water quality	2	3	14	17
Service leaks (City side)	1	0	2	3
Work done by Meter Service Team				
	<u>Nov 12</u>	<u>Nov 13</u>	<u>YTD 12</u>	<u>YTD 13</u>
New accounts set with 3/4" or 1"	12	14	126	218
New accounts set with larger meter	0	0	4	1
Meters tested	38	17	1291	379
Meters failed	0	0	18	2
Meters stalled	2	3	25	28
Service calls	130	68	995	1138
Final readings	426	306	3670	3741
Read meters - no reading	8	32	136	180
Defective trace replaced	7	6	31	10
Exception meters inspected	0	0	1	0
Exception meters removed	0	0	2	1
Service leaks found	0	0	7	3
Batteries changed	14	3	1149	122

**WATER MAIN BREAK/JOINT LEAK REPORT NOVEMBER
2013**

LOCATION	Work Order	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	ESTIMATED DOLLAR VALUE OF WATER REVENUE LOSS**
720 E. Summer Street	167950	DIP	12"	1976	3" hole	4 hours	360,000	\$2,189.84
621 E. Florida Avenue	168122	CIP	8"	1963	1/16" crack	6 hours	91,200	\$554.76
1409 N. Erb Street	168229	CIP	8"	1966	1/16" crack	1 day	364,800	\$2,219.04
908 E. Northwood Drive	168565	CIP	8"	1969	1/16" crack	6 hours	91,200	\$554.76
1000 Blk E. Park Ridge Avenue	168626	CIP	8"	1969	1/16" crack	6 hours	91,200	\$554.76
100 Blk E. Franklin Street	168627	CIP	6"	1939	3" hole	3 hours	270,000	\$1,642.38
Bennett Street/Welland Avenue	168628	CIP	8"	1969	1/16" crack	6 hours	91,200	\$554.76
1513 E. Plaza Drive	168971	CIP	8"	1964	1/16" crack	6 hours	91,200	\$554.76
Douglas Street/Haskel Street	168989	CIP	6"	1936	1/16" crack	6 hours	68,400	\$416.07
								\$0.00

**Water loss is calculated at the residential rate of \$4.55 per 100 cubic feet.

**WATER MAIN BREAK/JOINT LEAK DATA LOG NOVEMBER
2013**

Leak Location	Arterial, Collector, Freeway, Local	Type of Street Concrete/Ashpalt	Major Break /Minor Break	Catch Basin Draining Yes/No	Date/Time	Comments
720 E. Summer Street	Arterial	Concrete	Major	Yes 300' away	11/2/2013 8:30 a.m. Saturday	Fixed right away. A lot of water on a busy corner.
621 E. Florida Avenue	Local	Concrete	Major	Yes 100' away	11/4/2013 10:00 a.m. Monday	Had to let run until school let out at 3:20 p.m.
1409 N. Erb Street	Local	Asphalt	Minor	Yes 300' away	11/7/2013 6:00 p.m. Thursday	Let run until the next day and fixed during normal work hours.
908 E. Northwood Drive	Local	Concrete	Major	Yes 100' away	11/14/2013 7:00 p.m. Thursday	Fixed right away. This is a busy street.
1000 Blk E. Park Ridge Avenue	Local	Concrete	Major	Yes 250' away	11/15/2013 8:00 a.m. Friday	Fixed during normal work hours.
100 Blk E. Franklin Street	Arterial	Concrete	Major	Yes 100' away	11/15/2013 8:00 a.m. Friday	Fixed during normal work hours.

**WATER MAIN BREAK/JOINT LEAK DATA LOG NOVEMBER
2013**

Leak Location	Arterial, Collector, Freeway, Local	Type of Street Concrete/Ashpalt	Major Break Minor Break	Catch Basin Draining Yes/No	Date/Time	Comments
Bennett Street/Weiland Avenue	Local	Concrete	Major	Yes 75' away	11/16/2013 3:00 a.m. Saturday	Fixed right away. On a bus route and water was coming up on both sides of the street.
1513 E. Plaza Drive	Local	Concrete	Minor	Yes 150' away	11/26/2013 7:00 a.m. Tuesday	Fixed during normal work hours.
Douglas Street/ Haskel Street	Local	Asphalt	Major	Yes 50' away	11/27/2013 2:00 a.m. Wednesday	Fixed right away. Possible property damage.