

WATER MAIN BREAK/JOINT LEAK REPORT SEPTEMBER 2019

YEARLY WATER MAIN BREAK COMPARISON

<u>SEPT 18</u>	<u>SEPT 19</u>	<u>YTD 18</u>	<u>YTD 19</u>
2	4	52	57

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
1019 E. Meadow Grove Blvd.	260428	DIP	12"	1979	4" Hole	5 Hrs	1,074,425	\$6,532.50
1707 S. Driscoll St.	260640	CIP	8"	1956	3/4" Hole	3 Hrs	39,235	\$238.55
2911 N. Ballard	261014	DIP	12"	1971	3/4" Hole	11 Hrs	54,851	\$333.49
S. Linwood Ave & 8th St.	261133	DIP	12"	1980	3"x3" Hole	2.5 Hrs	380,000	\$2,310.40
								\$0.00
								\$0.00
								\$0.00
								\$0.00

**Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.