

WATER MAIN BREAK/JOINT LEAK REPORT APRIL 2019

YEARLY WATER MAIN BREAK COMPARISON

<u>MAR 18</u>	<u>MAR 19</u>	<u>YTD 18</u>	<u>YTD 19</u>
3	4	37	42

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
2631 N. Meade Street	254738	CIP	8"	1960	1/16" crack	3 hours	40,772	\$247.89
509 N. Kensington Drive	254816	CIP	8"	1967	1/16" crack	8 hours	147,380	\$896.07
1725 Hycrest Drive	254825	CIP	6"	1948	1/16" crack	7 days	1,380,585	\$8,393.96
White Birch Lane / Scarlet Oak Lane	255244	DIP	8"	1979	5" hole	3 hours	557,212	\$3,387.85
								\$0.00
								\$0.00
								\$0.00
								\$0.00

**Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.