

WATER MAIN BREAK/JOINT LEAK REPORT JUNE 2019

YEARLY WATER MAIN BREAK COMPARISON

<u>JUNE 18</u>	<u>JUNE 19</u>	<u>YTD 18</u>	<u>YTD 19</u>
2	3	42	49

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
323 N. Christine Street	257087	CIP	6"	1954	2 holes	5 hours	362,414	\$2,203.48
2906 E. Newberry Street	257148	CIP	12"	1963	6"	3.5 hours	1,276,351	\$7,760.21
Pine/Prospect Ave.	257620	CIP	6"	1935	18" split	3 hours	522,354	\$3,175.91
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00

**Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.