

WATER MAIN BREAK/JOINT LEAK REPORT OCTOBER 2019

YEARLY WATER MAIN BREAK COMPARISON

<u>OCT 18</u>	<u>OCT 19</u>	<u>YTD 18</u>	<u>YTD 19</u>
10	9	66	70

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
Fountain & Plaza	261937	CIP	8"	1964	1/8" Crack	4 Hours	97,246	\$591.26
935 W. Whittier Dr.	262086	CIP	8"	1964	1/16" Crack	4 Hours	70,919	\$431.19
Briarcliff & Crestview	262081	CIP	8"	1964	1/32" Crack 10" Split	40 Days	2,783,468	\$16,923.49
119 Lynn Dr.	262110	CIP	8"	1961	1/16" Hole	270 Days	256,410	\$1,558.97
231 S. Fidelis	262140	CIP	8"	1970	12"x1/64" Split	159 Days	6,921,189	\$42,080.83
612 E. Service Rd.	262323	CIP	12"	1961	1/64" Crack	24 Hours	134,818	\$819.69
719 S. Summit St.	262398	CIP	6"	1927	3" Hole	10 Hours	560,823	\$3,409.80
1020 N. Rankin St.	262473	CIP	8"	1945	1 1/2" Hole	24 Hours	480,000	\$2,918.40

**Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.

WATER MAIN BREAK/JOINT LEAK REPORT OCTOBER 2019

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
Roemer & Winslow	262471	CIP	12"	1978	3" Hole	4 Hours	480,000	\$2,918.40
								\$0.00

**Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.