

# WATER MAIN BREAK/JOINT LEAK REPORT JANUARY 2020

## YEARLY WATER MAIN BREAK COMPARISON

<u>JAN 19</u>	<u>JAN 20</u>	<u>YTD 19</u>	<u>YTD 20</u>
12	11	12	11

LOCATION	WORK ORDER	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	DOLLAR VALUE OF WATER REVENUE LOSS**
501 E. Roeland Ave.	265345	CIP	8"	1960	8" Split	36 hrs	37,445	\$227.67
5 Briarcliff Ct.	265742	CIP	8"	1964	1/32" Crack	24 hrs	172,979	\$1,051.71
Benoit & Spencer	265796	CIP	6"	1929	6" Hole	4 hrs	1,320,898	\$8,031.06
619 S. Mathias St.	265797	CIP	8"	1963	1/8" Crack	12 hrs	403,676	\$2,454.35
225 S. Telulah Ave	265869	CIP	4"	1927	1/8" Crack	6 hrs	54,700	\$332.58
707 E. McKinley St.	265902	CIP	6"	1947	1/8" Crack	3 hrs	58,819	\$357.62
508 W. Summer St.	265944	CIP	6"	1923	1/16" Crack	4 hrs	47,574	\$289.25
Lindbergh & Locust	266109	CIP	12"	1963	1/16" Crack	4 hrs	79,478	\$483.23

\*\*Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.

**WATER MAIN BREAK/JOINT LEAK REPORT JANUARY 2020**

<b>LOCATION</b>	<b>WORK ORDER</b>	<b>TYPE OF PIPE</b>	<b>SIZE</b>	<b>YEAR</b>	<b>BREAK</b>	<b>ESTIMATED DURATION</b>	<b>ESTIMATED WATER LOSS IN GALLONS</b>	<b>DOLLAR VALUE OF WATER REVENUE LOSS**</b>
909 E. Harrison St.	266206	CIP	6"	1946	1/16" Crack	4 hrs	40,772	\$247.89
400 Block N. Oneida St.	266419	CIP	6"	1935	1/8" Crack	4 hrs	70,618	\$429.36
Crestview & Canterbury	266499	CIP	8"	1966	1/64" Crack	7 days	638,176	\$3,880.11

\*\*Water Loss is calculated at the residential rate of \$6.08 per 1000 gallons.