

City of Appleton

100 North Appleton Street Appleton, WI 54911-4799 www.appleton.org

Meeting Agenda - Final Board of Building Inspection

Monday, June 21, 2021 3:00 PM 6th Floor Council Chambers

- 1. Call meeting to order
- 2. Roll call of membership
- 3. Approval of minutes from previous meeting
- 4. Public Hearings/Appearances

21-0898 Minutes from April 28, 2021

Attachments: Minutes 4-28-21.pdf

5. Action Items

21-0896

700 S. Weimar St. (31-4-1709-00) The existing stairs leading to the basement has one riser that is nine (9) inches. Section 321.04(2)(b) of the Uniform Dwelling Code (UDC) limits riser height to eight (8) inches and uniform.

Attachments: 700 S. Weimar St.pdf

21-0897

700 S. Weimar St. (31-4-1709-00) The existing headroom on the stair is 5' 8", Section 321.04(2)(d) of the UDC requires the headroom to be 6'4".

Attachments: 700 S. Weimar St.pdf

6. Information Items

7. Adjournment

Notice is hereby given that a quorum of the Common Council may be present during this meeting, although no Council action will be taken.

Reasonable Accommodations for Persons with Disabilities will be made upon Request and if Feasible.



City of Appleton

100 North Appleton Street Appleton, WI 54911-4799 www.appleton.org

Meeting Minutes - Final Board of Building Inspection

Wednesday, April 28, 2021

1:00 PM

6th Floor Council Chambers

Call meeting to order

Mayor Woodford called the meeting to order at 1:00 p.m.

2. Roll call of membership

Mike Smith's term expired before this meeting. Steve Patterson came as a representative of Battalion Chief Henson.

Present: 5 - Public Works Director Vandehey, City Attorney Behrens, Mayor Woodford,
Battalion Fire Chief Henson and Doran

Approval of minutes from previous meeting

21-0516

Minutes from April 28, 2020

Attachments:

4-28-20 Minutes.pdf

City Attorney Behrens moved, seconded by Public Works Director Vandehey, that the minutes be approved. Roll Call. Motion carried by the following vote:

Aye: 5 - Public Works Director Vandehey, City Attorney Behrens, Mayor Woodford,

Battalion Fire Chief Henson and Doran

Excused: 1 - Smith

4. Public Hearings/Appearances

Action Items

21-0490

300 N. Woods Edge Dr. (31-7-0003-00) Applicant proposes to renovate an office area that is within a building that exceeds the allowable area for a non-sprinkler, non-separated area, per Table 506.2 in the International Building Code, as adopted by Section 4-136. The office area is approximately 28' 3" by 42' 7".

Attachments:

300 N. Woods Edge Dr.pdf

Motion to approve variance contingent on a two hour fire wall installed to separate the area being renovated.

Public Works Director Vandehey moved, seconded by City Attorney Behrens,

that the Report Action Item be approved. Roll Call. Motion carried by the following vote:

Aye: 5 - Public Works Director Vandehey, City Attorney Behrens, Mayor Woodford, Battalion Fire Chief Henson and Doran

Excused: 1 - Smith

6. Information Items

7. Adjournment

A motion was made by Battalion Chief Henson, seconded by City Attorney Chris Behrens, that this meeting was adjourned at 1:13 p.m. The motion carried by the following vote:

Aye: 5 - Public Works Director Vandehey, City Attorney Behrens, Mayor Woodford, Battalion Fire Chief Henson and Doran

Excused: 1 - Smith

Return to:

Department of Public Works

Inspection Division 100 North Appleton Street Appleton, Wisconsin 54911

(920) 832-6411

City of Appleton Application for Board of Building Inspection

		y Information		
Address of Property (Variance Requested)		Parcel Number		
700 S. Weimar St Zoning District		Use X Residential □ Commercial		
R1B		Transferred Gommerviol		
	Annligan	at Information		
Owner Name		Applicant Information Owner Address		
Andrew Butler	700 3	700 S. Weimar St		
Owner Phone Number	Own	Owner E Mail address (optional)		
Agent Name		Agent Address N179 Alex Dr.		
Alex Page	1 -0 - 13	Appleton, WI 5915		
Agent Phone Number		Agent E Mail address (optional)		
920-579-2826	alex	alexpage@pcrestimates.com		
	Variance	e Information		
Municipal Code Section(s) Proje	THE RESERVE OF THE PROPERTY OF THE PARTY OF			
있다. 이렇게 하고 있는 이 이렇게 프라이지요		1.06 Ceiling Height (as adopted by Section 4-140(a)		
Brief Description of Proposed Pr	oiect			
Brief Description of Froposed 11	Ojeci			
		ng remodeled. The existing stairs leading to the		
		Section 321.04(2)(b) of the Uniform Dwelling		
		I uniform. The existing ceiling height is five (5) feet		
eight (X) inches Section 371 U6 (of the Uniform	n Dwelling Code requires ceiling height to be at		



Board of building inspections,

Installation of a second handrailing on left side of stairs coming down. Also install head bump pad at the bottom of the stairs.

Alex Page (920)579-2826 Page Construction & Remodeling LLC (PCR) Commercial & Residential Alexpage@PCRestimates.com

Return to:

Department of Public Works

Inspection Division 100 North Appleton Street Appleton, Wisconsin 54911

(920) 832-6411

City of Appleton Application for Board of Building Inspection

		y Information		
Address of Property (Variance Requested)		Parcel Number		
700 S. Weimar St Zoning District		Use X Residential □ Commercial		
R1B		Transferred Gommerviol		
	Annligan	at Information		
Owner Name		Applicant Information Owner Address		
Andrew Butler	700 3	700 S. Weimar St		
Owner Phone Number	Own	Owner E Mail address (optional)		
Agent Name		Agent Address N179 Alex Dr.		
Alex Page	1 -0 - 13	Appleton, WI 5915		
Agent Phone Number		Agent E Mail address (optional)		
920-579-2826	alex	alexpage@pcrestimates.com		
	Variance	e Information		
Municipal Code Section(s) Proje	THE RESERVE OF THE PROPERTY OF THE PARTY OF			
있다. 이렇게 하고 있는 이 이렇게 프라이지요		1.06 Ceiling Height (as adopted by Section 4-140(a)		
Brief Description of Proposed Pr	oiect			
Brief Description of Froposed 11	Ojeci			
		ng remodeled. The existing stairs leading to the		
		Section 321.04(2)(b) of the Uniform Dwelling		
		I uniform. The existing ceiling height is five (5) feet		
eight (X) inches Section 371 U6 (of the Uniform	n Dwelling Code requires ceiling height to be at		



Board of building inspections,

Installation of a second handrailing on left side of stairs coming down. Also install head bump pad at the bottom of the stairs.

Alex Page (920)579-2826 Page Construction & Remodeling LLC (PCR) Commercial & Residential Alexpage@PCRestimates.com