

City of Appleton

Meeting Agenda - Final

Board of Building Inspection

- 1. Call meeting to order
- 2. Roll call of membership
- 3. Approval of minutes from previous meeting

<u>17-115</u> Minutes from May 4, 2016.

Attachments: May 4, 2016 Minutes.pdf

4. Public Hearings/Appearances

5. Action Items

17-116702 E. North Ave. (31-1-0267-00). The applicant proposed construction
of a guardrail that is twenty-seven (27) inches tall. Section 321-04(3)(c)
of the Uniform Dwelling Code requires that quardrails are thirty-six(36)
inches tall.

Attachments: 702 E. North Ave Application and pictures.pdf

6. Information Items

7. Adjournment

Notice is hereby given that a quorum of the Common Council may be present during this meeting, although no Council action will be taken.

Reasonable Accommodations for Persons with Disabilities will be made upon Request and if Feasible.