

**WATER MAIN BREAK/JOINT LEAK DATA LOG MAY
2015**

Leak Location	Arterial, Collector, Freeway, Local	Type of Street Concrete/Asphalt	Major Break Minor Break	Catch Basin Draining Yes/No	Date/Time	Comments
2018 S. Greenvew Street	Local	Asphalt	Major	Yes 200' away	5/5/2015 12:00 p.m. Tuesday	Fixed right away. There was a lot of water.
700 Blk W. Weiland Avenue	Local	Asphalt	Major	Yes 5' away	5/8/2015 10:00 a.m. Friday	Leak found during repair to a manhole at Pershing Street and Locust Street. Traced the leak back to Weiland Avenue. Had been running a long time and not coming to the surface.

**WATER MAIN BREAK/JOINT LEAK DATA LOG MAY
2015**

Leak Location	Arterial, Collector, Freeway, Local	Type of Street Concrete/Asphalt	Major Break Minor Break	Catch Basin Draining Yes/No	Date/Time	Comments

WATER SUMMARY FOR MAY 2015

Work done by Construction Maintenance				
	<u>May 14</u>	<u>May 15</u>	<u>YTD 14</u>	<u>YTD 15</u>
Hydrants repaired	14	5	50	23
Hydrants replaced	1	0	1	6
Hydrant leaks	0	0	0	1
Valves replaced	0	0	4	0
Valves tested & inspected	0	0	0	0
Valves Rebuilt	0	0	14	5
Valve boxes repaired	28	33	60	95
Curb boxes repaired	36	49	76	149
Curb boxes replaced	2	3	40	32
Lead or galvanized replaced	0	0	0	0
New services 1"	0	0	0	0
New services >1"	0	1	0	2
Water main breaks	5	2	90	42
Joint leaks repaired	0	0	1	1
Water quality	4	0	5	1
Service leaks (City side)	0	0	2	0
Work done by Meter Service Team				
	<u>May 14</u>	<u>May 15</u>	<u>YTD 14</u>	<u>YTD 15</u>
New accounts set with 3/4" or 1"	2	17	10	47
New accounts set with larger meter	0	0	2	1
Meters tested	345	764	691	2984
Meters failed	0	0	0	0
Meters stalled	1	0	3	0
Service calls	174	168	769	674
Final readings	362	327	1472	1342
Read meters - no reading	17	0	176	0
New meters installed	0	638	0	3027
Exception meters inspected	0	0	2	0
Exception meters removed	0	0	1	0
Service leaks found	0	1	5	2
Cross connection inspections	357	605	357	2831

**WATER MAIN BREAK/JOINT LEAK REPORT MAY
2015**

LOCATION	Work Order	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	ESTIMATED DOLLAR VALUE OF WATER REVENUE LOSS**
2018 S. Greenview Street	194256	CIP	8"	1955	3" hole	6 hours	540,000	\$3,284.76
700 Blk W. Weiland Avenue	194383	CIP	8"	1969	1/16" crack	14 days	5,107,200	\$31,066.52
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00

**Water loss is calculated at the residential rate of \$4.55 per 100 cubic feet.