

**Strand Associates, Inc.®**

910 West Wingra Drive

Madison, WI 53715

(P) 608-251-4843

(F) 608-251-8655

June 15, 2015

CHANGE ORDER NO. 3

PROJECT: Bar Screen Replacement Project
OWNER: City of Appleton
CONTRACT: 1-2013
CONTRACTOR: August Winter and Sons, Inc.

Description of Change

3a	Modify Plexiglas access panel on bar screens.	ADD	\$1,650.00
TOTAL VALUE OF THIS CHANGE ORDER:		ADD	\$1,650.00



Contract Price Adjustment

Original Contract Price	\$744,247.00
Previous Change Order Adjustments	\$13,325.00
Adjustment in Contract Price this Change Order	\$1,650.00
Current Contract Price including this Change Order	\$745,897.00

Contract Completion Date Adjustment

Original Contract Completion Date	July 19, 2015
Contract Completion Date Adjustments due to previous Change Orders	0 days
Contract Completion Date Adjustments due to this Change Order	0 days
Current Contract Completion Dates including all Change Orders	July 19, 2015

This document shall become a supplement to the Contract and all provisions will apply hereto.

RECOMMENDED
ENGINEER—Strand Associates, Inc.®Date 6/15/15**APPROVED**
CONTRACTOR—August Winter and Sons, Inc.Date 6/16/15**APPROVED**
OWNER—City of AppletonDate 6/26/15

Witthuhn, Vernon

From: Robert Kennedy <Robert.Kennedy@Appleton.org>
Sent: Monday, June 15, 2015 6:10 AM
To: Van Grinsven, Kurt
Cc: Beinlich, Kevin; Witthuhn, Vernon
Subject: RE: Access covers

Follow Up Flag: Follow up
Flag Status: Completed

That is what I and my staff would like to see happen.
Vern, can you put a change order together for this?
Thanks
Bob

From: Van Grinsven, Kurt [mailto:kvangrinsven@augustwinter.com]
Sent: Friday, June 12, 2015 1:48 PM
To: Robert Kennedy
Cc: Beinlich, Kevin
Subject: Access covers

Bob,

Kevin met with you earlier today and talking with him we plan on stich welding stainless 304 angle iron on the top and bottom of the bar screens windows to form a "channel" to allow the plexi-glass to slide in and out from. Also, regarding the large bar screen we will cut the plexi-glass in half (vertical) to allow easier removal of the covers. We propose the work mentioned above for the amount of \$1650, If you have any questions feel free to contact me.

Kurt Van Grinsven

August Winter & Sons Inc.
Project Manager
Ph (920) 739-8881 Fax (920) 739-2230
Direct Ph (920) 560-2229
kvangrinsven@augustwinter.com