

WATER SUMMARY FOR JULY 2015

Work done by Construction Maintenance				
	<u>July 14</u>	<u>July 15</u>	<u>YTD 14</u>	<u>YTD 15</u>
Hydrants repaired	0	8	83	41
Hydrants replaced	0	0	2	6
Hydrant leaks	0	0	0	1
Valves replaced	0	4	6	4
Valves tested & inspected	0	0	0	17
Valves Rebuilt	6	3	21	9
Valve boxes repaired	19	17	111	119
Curb boxes repaired	22	64	142	300
Curb boxes replaced	38	27	124	91
Lead or galvanized replaced	0	0	0	0
New services 1"	0	0	0	0
New services >1"	1	0	5	3
Water main breaks	8	1	104	47
Joint leaks repaired	0	0	1	1
Water quality	3	0	10	2
Service leaks (City side)	1	0	3	0
Work done by Meter Service Team				
	<u>July 14</u>	<u>July 15</u>	<u>YTD 14</u>	<u>YTD 15</u>
New accounts set with 3/4" or 1"	1	15	13	64
New accounts set with larger meter	0	2	2	3
Meters tested	159	514	1527	4241
Meters failed	0	65	0	80
Meters stalled	0	1	3	2
Service calls	90	0	958	814
Final readings	383	518	2242	2276
Read meters - no reading	0	0	205	0
New meters installed	0	673	0	4448
Exception meters inspected	0	0	2	0
Exception meters removed	0	0	1	0
Service leaks found	0	0	6	2
Cross connection inspections	296	577	1130	4125

**WATER MAIN BREAK/Joint LEAK REPORT JULY
2015**

LOCATION	Work Order	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	ESTIMATED DOLLAR VALUE OF WATER REVENUE LOSS**
708 N. Briarcliff Drive	196956	CIP	8"	1964	4" hole	5 hours	839,121	\$5,104.28
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00

**Water loss is calculated at the residential rate of \$4.55 per 100 cubic feet.

**WATER MAIN BREAK/JOINT LEAK DATA LOG JULY
2015**

Leak Location	Arterial, Collector, Freeway, Local	Type of Street Concrete/Asphalt	Major Break Minor Break	Catch Basin Draining Yes/No	Date/Time	Comments
708 N. Briardliff Drive	Collector	Concrete	Major	Yes 150' away	7/20/2015 3:30 a.m. Monday	Third shift throttled down and it was repaired the next morning during normal working hours.