

WATER SUMMARY FOR MAY 2016

Work done by Construction Maintenance				
	<u>May 15</u>	<u>May 16</u>	<u>YTD 15</u>	<u>YTD 16</u>
Hydrants repaired	5	2	23	9
Hydrants replaced	0	0	6	2
Hydrant leaks	0	0	1	1
Valves replaced	0	0	0	1
Valves tested & inspected	0	0	0	559
Valves Rebuilt	0	0	5	0
Valve boxes repaired	33	2	95	24
Curb boxes repaired	49	14	149	66
Curb boxes replaced	3	8	32	17
Lead or galvanized replaced	0	2	0	2
New services 1"	0	0	0	0
New services >1"	1	0	2	1
Water main breaks	2	1	42	21
Joint leaks repaired	0	0	1	0
Water quality	0	0	1	0
Service leaks (City side)	0	0	0	1
Work done by Meter Service Team				
	<u>May 15</u>	<u>May 16</u>	<u>YTD 15</u>	<u>YTD 16</u>
New accounts set with 3/4" or 1"	17	15	47	55
New accounts set with larger meter	0	0	1	1
Meters tested	764	715	2984	3934
Meters failed	0	32	0	293
Meters stalled	0	0	0	0
Service calls	168	103	674	642
Final readings	327	376	1342	1392
Read meters - no reading	0	0	0	0
New meters installed	638	688	3027	4065
Exception meters inspected	0	0	0	0
Exception meters removed	0	0	0	0
Service leaks found	1	3	2	23
Cross connection inspections	605	698	2831	3815

**WATER MAIN BREAK/JOINT LEAK DATA LOG MAY
2016**

Leak Location	Arterial, Collector, Freeway, Local	Type of Street Concrete/Ashpalt	Major Break Minor Break	Catch Basin Draining Yes/No	Date/Time	Comments
34 Partridge Court	Local	Concrete	Major	Yes 100' away	5/25/2016 7:30 p.m. Wednesday	Fixed right away due to road damage and potential property damage.

**WATER MAIN BREAK/Joint LEAK REPORT MAY
2016**

LOCATION	Work Order	TYPE OF PIPE	SIZE	YEAR	BREAK	ESTIMATED DURATION	ESTIMATED WATER LOSS IN GALLONS	ESTIMATED DOLLAR VALUE OF WATER REVENUE LOSS**
34 Partridge Court	210971	DIP	8"	1978	4" hole	6 hours	972,458	\$5,915.35
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00
								\$0.00

**Water loss is calculated at the residential rate of \$4.55 per 100 cubic feet.