



Legislation Details (With Text)

File #: 21-1067 **Version:** 1 **Name:**
Type: Report Action Item **Status:** Action Item
File created: 7/22/2021 **In control:** Board of Building Inspection
On agenda: 8/2/2021 **Final action:** 8/2/2021
Title: 543 N. Union St. (31-1-0186-00) The applicant is proposing to construct a landing that is 32" wide. SPS 321.04(4)(2) requires landings to be 36" wide.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 543 N. Union St.pdf

Date	Ver.	Action By	Action	Result
8/2/2021	1	Board of Building Inspection	approved	Pass

543 N. Union St. (31-1-0186-00) The applicant is proposing to construct a landing that is 32" wide. SPS 321.04(4)(2) requires landings to be 36" wide.