



Legislation Details (With Text)

File #: 22-1508 **Version:** 1 **Name:**

Type: Report Action Item **Status:** Action Item

File created: 11/28/2022 **In control:** Board of Building Inspection

On agenda: 12/1/2022 **Final action:** 12/1/2022

Title: 724 S. Mueller St. (31-3-0737-00) Build interior stairs that have riser heights from 8 ¾ inches to 7 ¾ inches. SPS 321.04(2)(b) requires a maximum riser height of 8 inches. Build an interior stairs with headroom that is 72", SPS 321.04(2)(d) requires headroom to be 76", contingent on a padding be added to the ceiling.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 724 S. Mueller St.pdf

Date	Ver.	Action By	Action	Result
12/1/2022	1	Board of Building Inspection	approved as amended	Pass

724 S. Mueller St. (31-3-0737-00) ~~Build interior stairs that have riser heights from 8 ¾ inches to 7 ¾ inches. SPS 321.04(2)(b) requires a maximum riser height of 8 inches.~~ Build an interior stairs with headroom that is 72", SPS 321.04(2)(d) requires headroom to be 76", contingent on a padding be added to the ceiling.