



Legislation Details (With Text)

File #: 21-0897 **Version:** 1 **Name:**
Type: Report Action Item **Status:** Action Item
File created: 6/16/2021 **In control:** Board of Building Inspection
On agenda: 6/21/2021 **Final action:** 6/21/2021
Title: 700 S. Weimar St. (31-4-1709-00) The existing headroom on the stair is 5' 8", Section 321.04(2)(d) of the UDC requires the headroom to be 6'4".

Sponsors:

Indexes:

Code sections:

Attachments: 1. 700 S. Weimar St.pdf

Date	Ver.	Action By	Action	Result
6/21/2021	1	Board of Building Inspection	approved	Pass

700 S. Weimar St. (31-4-1709-00) The existing headroom on the stair is 5' 8", Section 321.04(2)(d) of the UDC requires the headroom to be 6'4".