



# City of Appleton

100 North Appleton Street  
Appleton, WI 54911-4799  
www.appleton.org

## Legislation Text

---

File #: 22-1508, Version: 1

---

**724 S. Mueller St. (31-3-0737-00)** ~~Build interior stairs that have riser heights from 8  $\frac{3}{4}$  inches to 7  $\frac{3}{4}$  inches. SPS 321.04(2)(b) requires a maximum riser height of 8 inches.~~ Build an interior stairs with headroom that is 72", SPS 321.04(2)(d) requires headroom to be 76", contingent on a padding be added to the ceiling.