

City of Appleton

100 North Appleton Street Appleton, WI 54911-4799 www.appleton.org

Legislation Text

File #: 21-0897, Version: 1

700 S. Weimar St. (31-4-1709-00) The existing headroom on the stair is 5' 8", Section 321.04(2)(d) of the UDC requires the headroom to be 6'4".