



## Legislation Details

---

**File #:** 21-1067      **Version:** 1      **Name:**  
**Type:** Report Action Item      **Status:** Action Item  
**File created:** 7/22/2021      **In control:** Board of Building Inspection  
**On agenda:** 8/2/2021      **Final action:** 8/2/2021  
**Title:** 543 N. Union St. (31-1-0186-00) The applicant is proposing to construct a landing that is 32" wide. SPS 321.04(4)(2) requires landings to be 36" wide.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 543 N. Union St.pdf

Date	Ver.	Action By	Action	Result
8/2/2021	1	Board of Building Inspection	approved	Pass