



## Legislation Details

---

**File #:** 22-1508      **Version:** 1      **Name:**  
**Type:** Report Action Item      **Status:** Action Item  
**File created:** 11/28/2022      **In control:** Board of Building Inspection  
**On agenda:** 12/1/2022      **Final action:** 12/1/2022  
**Title:** 724 S. Mueller St. (31-3-0737-00) Build interior stairs that have riser heights from 8  $\frac{3}{4}$  inches to 7  $\frac{3}{4}$  inches. SPS 321.04(2)(b) requires a maximum riser height of 8 inches. Build an interior stairs with headroom that is 72", SPS 321.04(2)(d) requires headroom to be 76", contingent on a padding be added to the ceiling.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 724 S. Mueller St.pdf

Date	Ver.	Action By	Action	Result
12/1/2022	1	Board of Building Inspection	approved as amended	Pass