



## Legislation Details

---

**File #:** 21-1313      **Version:** 1      **Name:**  
**Type:** Report Action Item      **Status:** Action Item  
**File created:** 9/14/2021      **In control:** Board of Building Inspection  
**On agenda:** 9/15/2021      **Final action:** 9/15/2021  
**Title:** 5300 N. Meade St. (31-1-8500-00) The Applicant is proposing to construct an athletic storage building with the stair riser height to be 8" and the tread depth to be 9". Section 4-136 of the Municipal Code (IBC 1011.5.2 of the Commercial Code) requires riser height to be a maximum of 7" and tread depth to be a minimum of 11".

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 5300 N. Meade St.pdf

Date	Ver.	Action By	Action	Result
9/15/2021	1	Board of Building Inspection	approved	Pass